



Office: (325)658-2961

8174 HWY 87 North, San Angelo, TX 76901

Email: Conchoruralwater@gmail.com

Mandatory Language for a Maximum Contaminant Level Violation - TTHM

The Texas Commission on Environmental Quality (TCEQ) has notified the Concho Rural Water Pecan Creek TX2260057 public water system that the drinking water being supplied to customers had exceeded the Maximum Contaminant Level (MCL) for total trihalomethanes. The U.S. Environmental Protection Agency (U.S. EPA) has established the MCL for total trihalomethanes to be 0.080 milligrams per liter (mg/L) based on a locational running annual average (LRAA), and has determined that it is a health concern at levels above the MCL. Analysis of drinking water in your community for total trihalomethanes indicates a compliance value in quarter three 2024 of 0.081 mg/L for DBP2-01.

Trihalomethanes are a group of volatile organic compounds that are formed when chlorine, added to the water during the treatment process for disinfection, reacts with naturally-occurring organic matter in the water.

Some people who drink water containing trihalomethanes in excess of the MCL over many years may experience problems with their liver, kidney, or central nervous systems, and may have an increased risk of getting cancer.

You do not need to use an alternative water supply. However, if you have health concerns, you may want to talk to your doctor to get more information about how this may affect you.

We are taking the following actions to address this issue: CRWC is receiving high levels of TTHMs from the water which is purchased from the City of San Angelo. CRWC was advised by COSA officials that COSA's water treatment plant was undergoing upgrades. They advised that the problem with the high levels of TTHMs would be resolved once the plant is running. The water plant is supposed to be operational by March of 2025. CRWC plans on using more groundwater while San Angelo's treatment plant is not operational.

Please share this information with all people who drink this water, especially those who may not have received this notice directly (i.e., people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

If you have questions regarding this matter, you may contact Ben Wiese at 325-658-2961.

Posted /Delivered on: 11-14-24

**Respectfully,
Ben Wiese
President,
Concho Rural Water Corporation**
